SERVICING & STORMWATER MANAGEMENT IMPLEMENTATION REPORT

629 HURONTARIO STREET

TOWN OF COLLINGWOOD SIMCOE COUNTY

PREPARED FOR:

DR. SUSAN O'TOOLE

PREPARED BY:

C.F. CROZIER & ASSOCIATES INC. 70 HURON STREET, SUITE 100 COLLINGWOOD, ON L9Y 4L4

FEBRUARY 2025

CFCA FILE NO. 2361-7140

The material in this report reflects best judgment in light of the information available at the time of preparation. Any use which a third party makes of this report, or any reliance on or decisions made based on it, are the responsibilities of such third parties. C.F. Crozier & Associates Inc. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.



Revision Number	Date	Comments
Rev.0	August 2023	1st Submission (OPA/ZBA)
Rev.1	July 2024	1st Submission (SPA)
Rev.2	February 2025	4 th Submission (SPA)

TABLE OF CONTENTS

1.0	INT	RODUCTION	1
2.0	SIT	E DESCRIPTION & BACKGROUND	1
3.0	TRA	ANSPORTATION	2
4.0	GR	ADING	2
5.0	WA	ATER SUPPLY	2
	5.1 5.1.1	Existing Potable Water Supply Infrastructure	
	5.2 5.2.1 5.2.2 5.2.3	Water Demand Existing Domestic Water Demand Proposed Domestic Water Demand Fire Flow Demand	2 3
	5.3	Proposed Water Servicing Strategy	3
6.0	SA	NITARY SERVICING	4
	6.1 6.1.1	Existing Sanitary Sewer Infrastructure	
	6.2 6.2.1 6.2.2	Sanitary Demand Existing Sanitary Demand Proposed Sanitary Demand	4
	6.3	Proposed Sanitary Servicing Strategy	5
7.0	STC	DRMWATER MANAGEMENT AND SITE DRAINAGE	5
	7.1 7.2 7.3 7.4 7.5	Stormwater Management Criteria	5 6 6
8.0	UTI	LITIES	8
9.0	ERG	OSION & SEDIMENT CONTROLS	8
10.	0 CC	ONCLUSIONS AND RECOMMENDATIONS	9

LIST OF TABLES

Table 1: Pre- and Post-Development Peak Flow Rates

 Table 2:
 Storage Requirements for 5-year and 100-year Post-Development Storm

Events

LIST OF APPENDICES

Appendix A: As-Recorded Information

Appendix B: Water Demand and Fire Flow Calculations

Appendix C: Sanitary Demand Calculations

Appendix D: Topographic Survey (Van Harten Surveying Inc., December 2022)

Appendix E: Modified Rational Method Calculations

Appendix F: Oil/Grit Separator Sizing Report

LIST OF FIGURES

Figure 1: Site Location Plan

Figure 2: Site Plan

Figure 3: Pre-Development Drainage Plan

Figure 4: Post-Development Drainage Plan

LIST OF DRAWINGS

Drawing C102: Removals and Erosion & Sediment Control Plan

Drawing C103: Servicing Plan
Drawing C104: Grading Plan

Drawing C105 - C106: Standard Notes & Details

Drawings E100-101: Site Photometric Plan & Site Lighting Details

1.0 INTRODUCTION

C.F. Crozier & Associates Inc. (Crozier) was retained by Dr. Susan O'Toole to prepare a Servicing & Stormwater Management Implementation Report in support of a Site Plan Approval (SPA) application for the proposed change of use for the existing dwelling located at 629 Hurontario Street, Town of Collingwood, Simcoe County. Crozier has previously completed a Functional Servicing & Preliminary Stormwater Management Report in support of the Official Plan Amendment and Zoning By-law Amendment Applications for the proposed development. For this report, the property, which is subject to the SPA application, will be referred to as the "Site". The location of the Site is reflected on the Site Location Plan included as **Figure 1**.

This Servicing & Stormwater Management Implementation Report provides information about the existing water and sanitary servicing and outlines the proposed stormwater management (SWM) strategy required to service the Site.

External documents/plans were reviewed over the course of completing this engineering report. As such, the servicing and design considerations contained herein are assisted by the following:

- Town of Collingwood Development Standards (2007, amended 2022)
- As-Constructed Drawings along Hurontario Street and Collins Street (Greenland Consulting Engineers, 2011)
- Plan of Survey (Van Harten Surveying Inc., 2022)
- Traffic Impact Brief (Crozier, 2023)
- Functional Servicing & Preliminary Stormwater Management Report (Crozier, 2023)

2.0 SITE DESCRIPTION & BACKGROUND

The Site covers an area of approximately 0.1 ha and currently consists of a residential dwelling and detached garage. The Site has been recently rezoned under Town File No. D0840323 from Residential (R2) to Mixed Use Commercial – Exception (C4XX) in the Town of Collingwood Zoning By-Law (2018, amended 2023). The property, located in a residential neighbourhood, is bound by Collins Street to the north, residential land uses to the east and south, as well as Hurontario Street and the Collingwood Collegiate Institute to the west. The existing Site currently has two (2) entrances from Collins Street; one entrance leads to the detached garage; the second entrance leads to the existing gravel parking area. These two (2) existing entrances will be removed, and a new entrance will be installed to service the proposed parking lot area.

The existing residential building on the Site is proposed to be re-purposed into a medical office. The existing gravel parking area and backyard is proposed to be re-purposed into an asphalt parking lot for the medical office, with a single access from Collins Street to replace the two existing entrances. This proposed parking lot is shown on the Site Plan, which has been included as **Figure 2** in this report.

3.0 TRANSPORTATION

Access to the Subject Development will be provided via one connection to Collins Street to the north of the Site. Within the Site, there will be a parking lot with eleven (11) parking spots (one spot is accessible) that will provide access to the proposed medical office. Refer to the Traffic Impact Brief (Crozier, 2023) for additional information regarding impacts to traffic in the area.

4.0 GRADING

The site grading will be influenced by the existing and proposed drainage systems within the Site. Grading will tie into the existing elevations along the property limits, match the pre-development overland stormwater flow patterns where possible, and provide sufficient cover for the proposed storm servicing infrastructure. A concrete toe wall per OPSD 3120.100 is proposed along the southwest corner of the parking lot to promote positive drainage from the parking lot to the proposed catchbasins. Refer to **Drawing C103** for the site grading plan and **Drawing C104A-B** for standard notes and details.

5.0 WATER SUPPLY

Potable water for the Site will be supplied by the Town of Collingwood municipal water distribution system.

5.1 Existing Potable Water Supply Infrastructure

5.1.1 Water Distribution System

The existing water distribution infrastructure at or near the Site includes the following:

- 200 mm diameter watermain on Collins Street
- 300 mm diameter watermain on Hurontario Street

An existing potable water connection to the 300 mm diameter watermain on Hurontario Street currently services the Site. The approximate location of the existing service lateral is shown on **Drawing C102**, which is based on the plan and profile drawings by Greenland Consulting Engineers (2011) provided in **Appendix A** of this report.

5.2 Water Demand

The Town of Collingwood Development Standards were referenced to calculate the existing water demand for the Site. The Ontario Building Code (2012) was referenced to calculate the proposed water demand for the Site.

5.2.1 Existing Domestic Water Demand

Water demands for the existing residential dwelling were determined in accordance with the design flows and peaking factors identified in Section 4.4.3.2 of the Collingwood Development Standards. The design criteria used to estimate existing domestic water demand include:

Average Residential Flow Rate
 Max Day/Peak Hour Factors
 1.77/2.70

Population Density
 2.9 Persons Per Unit

It is estimated that the maximum water demands for the existing development are as follows:

Average Day 0.009 L/sec
 Max Day 0.015 L/sec
 Peak Hour 0.024 L/sec

5.2.2 <u>Proposed Domestic Water Demand</u>

As noted in Section 2.0, the existing building is to be maintained on Site and converted into a medical office. It is anticipated that the medical office will employ four (4) practitioners and one (1) administrative employee. Water demands for the proposed medical office were determined in accordance with the design flows identified for commercial doctor's offices in Table 8.2.1.3 of the OBC. Peak factors were determined in accordance with the newly amended Town of Collingwood Engineering Standards (2022). The design criteria used to estimate domestic water demand include:

Commercial (Doctor's Office) Flow Rates
 275 L/practitioner/day

(OBC 8.2.1.3) 75 L/employee per 8-hour shift/day

Max Day/Peak Hour Factors
 1.77/2.70

It is estimated that the maximum water demands for the proposed development are as follows:

Average Day 0.014 L/sec
 Max Day 0.024 L/sec
 Peak Hour 0.037 L/sec

Refer to **Appendix B** for the water demand calculations.

5.2.3 Fire Flow Demand

Since the proposed change of use for the Site does not include any additions to the existing building, the fire flow calculations are the same under existing and proposed conditions. Fire flows required to service the site were determined to be 66.67 L/s per the Fire Underwriter's Survey (2020). Refer to **Appendix B** for the fire flow calculations.

Since the Site is located within a developed area consisting of other commercial, institutional, and residential properties, it is assumed that the Town's water distribution system provides adequate fire flows and that no external upgrades are required.

5.3 Proposed Water Servicing Strategy

Water servicing for the Site will be supplied by the existing water service connecting to the 300 mm diameter watermain on Hurontario Street.

6.0 SANITARY SERVICING

6.1 Existing Sanitary Sewer Infrastructure

6.1.1 Sanitary Sewer System

The existing sanitary sewer infrastructure at or near the Site consists of the following:

- 375 mm diameter sanitary sewer along Collins Street
- 450 mm diameter sanitary sewers along Hurontario Street

An existing sanitary connection to the 450 mm diameter sewer on Hurontario Street currently services the Site. The approximate location of the existing water service lateral is shown on **Drawing C102**, which is based on the plan and profile drawings by Greenland Consulting Engineers (2011) in **Appendix A**.

6.2 Sanitary Demand

The Town of Collingwood Development Standards were referenced to calculate the sanitary demand for the Site.

6.2.1 Existing Sanitary Demand

Sanitary flow rates for the existing residential dwelling were determined in accordance with the design parameters Section 4.3.3.1 of the Collingwood Development Standards. The design criteria used to estimate sanitary demand include:

Average Residential Flow Rate
 260 L/cap/day
 Infiltration
 0.23 L/s/ha

Persons Per Residential Unit
 2.9

Peaking Factor
 Harmon Formula

Based on these values it is estimated that existing peak sanitary flow from the Site is 0.062 L/s.

Refer to **Appendix C** for the sanitary demand calculations. The approximate location of the existing sanitary service lateral is shown on **Drawing C102**, which is based on the plan and profile drawings by Greenland Consulting Engineers (2011) in **Appendix A**.

6.2.2 Proposed Sanitary Demand

Sanitary flow rates for the proposed medical office were determined in accordance with the design parameters identified in Table 8.2.1.3 of the OBC (2012). The design criteria used to estimate sanitary demand includes:

Commercial (Doctor's Office) Flow Rates
 275 L/practitioner/day

(OBC 8.2.1.3) 75 L/employee per 8-hour shift/day

Infiltration
 0.23 L/s/ha

Persons Per Residential Unit
 2.9

Peaking Factor
 Harmon Formula

Based on these values it is estimated that peak sanitary flow from the Site will be 0.083 L/s.

Refer to **Appendix C** for the sanitary demand calculations.

6.3 Proposed Sanitary Servicing Strategy

Sanitary servicing for the Site will be supplied by the existing sanitary service connecting to the 450 mm diameter sanitary sewer on Hurontario Street.

7.0 STORMWATER MANAGEMENT AND SITE DRAINAGE

7.1 Stormwater Management Criteria

The management of stormwater and Site drainage for the entire Site must comply with the policies and standards of the various agencies including the Town of Collingwood and the Ministry of Environment, Conservation and Parks (MECP).

The stormwater management criteria for the future development include:

- Water Quantity Control
 - o 100-year post-development flow to 5-year pre-development flow control.
- Water Quality Control
 - Provide an Enhanced Level of Protection (80% TSS removal for 90% of the annual runoff).

7.2 Existing Drainage Conditions

A topographic survey was completed by Van Harten Surveying Inc. (December 2022), which has been included as **Appendix D** of this report. Upon review of the survey, our office determined that the Site drains towards existing catchbasins located within the boulevards on Collins Street and Hurontario Street, which collect runoff from the Site and conveys it to the existing storm sewers via 200 mm diameter catchbasin leads. The existing storm sewers adjacent to the site are listed below:

- 375 mm diameter storm sewer on Collins Street
- 400 mm diameter storm sewer on Hurontario Street

The topographic survey also indicates that a portion of the lot to the south of the Site may drain through the Site towards Collins Street. Both the internal and external drainage catchments have been shown on the Pre-Development Drainage Plan (Figure 3). To facilitate the pre-development stormwater analysis, the following five (5) catchments have been discretized based on the existing drainage conditions.

- Catchment 101: This catchment area is approximately 0.05 ha and is located in the western portion of the Site. It consists of the existing single detached dwelling, side and front lawn, and an existing paved walkway.
- Catchment 102: This catchment area is approximately 0.06 ha and is located in the eastern portion of the Site. It consists of the existing detached garage, existing driveway, existing wood deck, and lawn area.

C.F. Crozier & Associates Inc. Project No. 2361-7140

- External Catchment 1: This catchment area is approximately 0.01 ha and is located along the southern property line. It consists of an existing shed and lawn area.
- **External Catchment 2**: This catchment area is approximately 0.01 ha and is located along the southern property line. It consists of lawn area adjacent to the southern property line.

7.3 Proposed Drainage Conditions

Per the Town's development standards, the proposed drainage system within the development will be required to convey internal runoff to an appropriate outlet and all infrastructure must be sized accordingly. The stormwater outlet will be the existing storm sewer infrastructure on Collins Street, which is conveyed to the storm sewer on Hurontario Street.

Internal paved areas within the Site will be graded with varying slopes typically ranging from 0.5% - 5% to promote stormwater drainage from the parking area towards proposed catchbasins which connect to the existing storm sewer infrastructure on Collins Street.

The proposed reuse of the Site will not significantly alter the current drainage conditions. Under post-development conditions, the minor and major storm events will be collected via a storm sewer network within the proposed parking lot. A control structure, complete with an 85 mm diameter orifice plate, will be installed to ensure that the flow rates leaving the Site do not exceed pre-development peak flows. Connection to the Town's storm network will be made via the existing 200 mm diameter catchbasin lead on Collins Street.

External drainage will be collected by two proposed ditch inlet catchbasins in the south-east corner of the Site and conveyed through the proposed storm sewer network within the parking lot.

Refer to the Post-Development Drainage Plan shown in **Figure 4.** To facilitate the post-development stormwater analysis, the following five (5) catchments have been discretized based on the proposed drainage conditions.

- Catchment 201: This catchment area is approximately 0.05 ha and is located in the western
 portion of the Site. It consists of the proposed medical office, lawn area, and an existing paved
 walkway.
- Catchment 202: This catchment area is approximately 0.06 ha and is located in the eastern portion of the Site. It consists of the existing detached garage, proposed asphalt parking lot, proposed accessibility lift, and the Site entrance located along Collins Street.
- **External Catchment 1**: This catchment area is approximately 0.01 ha and is located along the southern property line. It consists of an existing shed and lawn area. It remains the same from pre-development drainage conditions.
- External Catchment 2: This catchment area is approximately 0.01 ha and is located along the southern property line. It consists of lawn area adjacent to the property line. It remains the same from pre-development drainage conditions.

7.4 Stormwater Quantity Control

Based on the Site Plan, the Site will have an increase in impervious area due to the addition of the proposed parking lot. Stormwater runoff for minor and major flow events will be directed to Collins Street via proposed stormwater infrastructure. Post-development peak flows will be controlled to meet

the existing pre-development 5-year peak flows through the use of an orifice plate within a control structure. Stormwater storage will be provided on-site through pipe, structure, and surface ponding within the proposed parking lot. In the event of a blockage, an emergency overland flow route is available to convey stormwater from the parking lot to Collins Street.

Per the Town of Collingwood Development Standards, the Modified Rational Method was used to calculate the pre- and post-development flow rate produced on Site for the 2-year to 100-year storm events. The Intensity-Duration-Frequency Curves for the Town, adapted from the Atmospheric Environment Services Owen Sound Station, were used in the calculations.

Runoff coefficients were estimated by measuring the impervious and pervious areas for the Site under pre- and post- development conditions. A weighted average was calculated to determine a design runoff coefficient for the Site in pre- and post-development which was used to estimate peak flows. Pre- and post-development flows are summarized below in **Table 1**. Refer to **Appendix E** for the Rational Method calculations.

Table 1. Pre- and Post-Development Peak Flow Rates

Pre-Development (m³/		Post-Developmen (m³	
5-year 100-year		5-year	100-year
0.018	0.030	0.022	0.036

The Modified Rational Method was used to calculate the storage requirements to control post-development flows to the 5-year pre-development peak flow rate. The storage requirements for the 5-year and 100-year post-development storm events are shown below in **Table 2**.

Table 2. Storage Requirements for 5-year and 100-year Post-Development Storm Events

5-Year Controlled	5-Year Storage	100-Year Controlled	100-Year Storage
Release Rate (m³/s)	Requirement (m³)	Release Rate (m³/s)	Requirement (m³)
0.018	3.1	0.018	13.7

A combination of stormwater infrastructure (structures, pipes, and surface ponding) is proposed to provide the 100-year storage requirement of 13.7 m³. A storage of 15.9 m³ is provided as shown below in **Table 3**.

Table 3. Storage Provided During 100-year Post-Development Storm Event

Type of Infrastructure	Description	Storage Provided (m³)
Structure	DICB1	0.71
Structure	DICB2	0.65
Structure	DCBMH2	1.96
Pipe	DICB1 to DCBMH2	0.54
Pipe	DICB2 to DCBMH2	0.61
Pipe	DCBMH2 to MH3	0.71
Ponding	Surface Ponding	10.70
	TOTAL	15.9

As shown on the Servicing Plan (**Drawing C102**), the three proposed 250 mm – 300 mm diameter pipes and three structures within the parking lot provide approximately 5.0 m³ of storage, while the surface

ponding provides an additional storage volume of approximately 10.7 m³. Therefore, the total storage volume of 15.9 m³ on Site exceeds the minimum storage required.

7.5 Stormwater Quality Control

An Oil-Grit-Separator (OGS) unit is proposed to be installed at the downstream end of the internal storm sewer system to protect water quality by ensuring runoff from the parking lot is treated before entering the Town's storm sewer system on Collins Street. To achieve an "enhanced" treatment level for the oil/grit separator, the unit must provide an annual total suspended solids (TSS) removal of 80% or greater and treat 90% of the total annual runoff volume. The Contech Engineered Solutions OGS model PMSU2015-4 was chosen to provide treatment for up to 90% TSS removal of fine particles from stormwater runoff from the 0.07 ha parking lot.

Refer to for a detailed breakdown of proposed oil/grit separator performance. Refer to **Appendix F** for the proposed Stormceptor water quality treatment unit sizing report.

Contributing Drainage Area (ha)	Contributing Area Percent Impervious (%)	Oil/Grit Separator Unit	Total Suspended Solids Removal (%)	Total Annual Runoff Volume Treated (%)
0.07	90	PMSU2015-4	90	>90

Table 4. Oil/Grit Separator Sizing Criteria

8.0 UTILITIES

The Site is to be serviced with existing natural gas, telephone, cable TV and hydro. The Site Lighting & Photometrics design can be found in **Drawings E100 – E101.**

9.0 EROSION & SEDIMENT CONTROLS

Erosion and sediment controls will be installed prior to the commencement of any earthworks and maintained throughout until the site is stabilized or as directed by the Engineer and/or Township. Controls are to be inspected regularly, after each significant rainfall, and maintained in proper working condition. Erosion and sediment controls measures to be considered include, but are not limited to, the following:

Silt Fence

Silt fence will be installed where required to intercept sheet flow. Heavy duty silt fence will be located around the perimeter of the work zone limits. It should be noted that additional silt fencing may be added based on field decisions by the Site Engineer and Owner prior to, during, and following construction.

Dust Suppression

During earthwork activities, the Contractor will ensure that measures for dust suppression are provided as required, such as the application of water or lime.

• Silt Sacks

Silt sacks will be installed on existing catchbasins to help filter silt and soil out of stormwater from the Site prior to entering the stormwater conveyance system.

10.0 CONCLUSIONS AND RECOMMENDATIONS

It is concluded that the proposed change of use for the Site can utilize the existing services and the proposed parking can be graded to maintain existing drainage conditions. The stormwater management strategy includes a combination of pipes, structures, and surface storage within the parking lot to provide quantity control, and an OGS unit to provide quality control.

We trust that this report will be sufficient in supporting the Site Plan Approval application. Should you have any questions or require further information, please do not hesitate to contact the undersigned. Thank you.

Respectfully submitted,

C.F. CROZIER & ASSOCIATES INC.


C.F. CROZIER & ASSOCIATES INC.


George Cooper, P.Eng. Project Manager Jonathon Kerschbaumer, P. Eng. Project Engineer

J:\2300\2361 - Dr. Susan O'Toole\7140 - 629 Hurontario St SPA\Reports\1st Submission - SPA\2024.07.26_Servicing & SWM Implementation Report.docx

APPENDIX A

As-Recorded Information





APPENDIX B

Water Demand and Fire Flow Calculations



File: 2361-6530
Date: July 8, 2024
By: DK/GC
Check By: GC/JK

629 Hurontario Street - Existing Domestic Water Demand

Developed Site Area 0.10 ha

Number of Residential Units and Land Usage

Person Per Residential Unit

1) Single Residential (Per Master Servicing Plan for Water and Sanitary Sewer Systems, 2019) 2.9 persons/unit

Total Residential Population 2.9 Persons

Domestic Water Design Flows

Residential (Per Town Standards)

260 L/C-day

Commercial (Per Master Servicing Plan for Water and Sanitary Sewer Systems, 2019) 21.6 m³/ha/d

Total Domestic Water Design Flows

Average Residential Daily Flow 0.009 L/sec

Max Day Peak Factor (Per Town Standards) 1.77

Max Day Demand Flow 0.015 L/sec

Peak Hour Factor (Per Town Standards)

Peak Hour Flow

2.70

0.024 L/sec



File: 2361-6530 Date: July 8, 2024 By: DK/GC Check By: GC/JK

629 Hurontario Street - Proposed Domestic Water Demand

Developed Site Area 0.10 ha

Number of Residential Units and Land Usage

1) Single Residential
2) Commercial Area

- Units
189 m²

Person Per Residential Unit

1) Single Residential (Per Town Standards) 2.9 persons/unit

Total Residential Population 5 Persons

Domestic Water Design Flows

Residential (Per Town Standards) 260 L/C-day

Commercial (Doctor's Office, Per OBC 8.2.1.3) 275 L/practitioner/d

75 L/employee per 8 hr shift/day

Total Domestic Water Design Flows

Average Residential Daily Flow 0.014 L/sec

Max Day Peak Factor (Per Town Standards) 1.77

Max Day Demand Flow 0.024 L/sec

Peak Hour Factor (Per Town Standards) 2.70

Peak Hour Flow 0.037 L/sec



Project Name: 629 Hurontario Street

Project No: 2361-6530 Prepared By: DK Checked By: GC Date: 2023-07-10

Water Supply for Public Fire Protection - 2020

Fire Underwriters Survey

Part II - Guide for Determination of Required Fire Flows for Public Fire Protection in Canada

An estimate of fire flow required for a given area may be determined by the formula:

RFF = 220 * C * sqrt A

where:

RFF = the required fire flow in litres per minute (L/min)

C = the construction coefficient is related to the type of construction of the building

= 1.5 for Type V Wood Frame Construction

= 0.8 for Type IV-A Mass Timber Construction

= 0.9 for Type IV-B Mass Timber Construction

= 1.0 for Type IV-C Mass Timber Construction

= 1.5 for Type IV-D Mass Timber Construction

= 1.0 for Type III Ordinary Construction

= 0.8 for Type II Non-combustible Construction

= 0.6 for Type I Fire Resistive Construction

A = the total effective floor area (effective building area) in square metres (excluding basements at least

50 percent below grade) in the building considered

Step A.	Construction Coefficient (C)	1.0	= 1.0 for Type III Ordinary Construction
		Yes/No/Unknown	
Is	s basement at least 50% below grade?	Yes	If yes, basement floor area excluded
	Vertical openings protected?	Unknown	*For consideration for effective area calculations

Step B. Proposed Building

Medical Office

Calculate Effective Floor Area based on the highlighted cell

-C value from 1.0 to 1.5: 100% of all floor areas are used

-C value below 1 and vertical openings are not protected: Consider two largest floors plus 50% of all floor above to a max of eight

-C value below 1 and vertical openings are protected: Consider single largest floor plus 25% of the two immediately adjoining floors

Floors Above Grade	Total Floor Area (m²)	% of Area Considered	Effective Floor Area (m ²)	
Basement		NA	NA	
Ground Floor	157.5	100%	157.5	*Includes detached garage
Level 2	61.8	100%	61.8	*A building may be subdivided if there is a vertical firewall with a
Level 3			0.0	fire-resistance rating greater than 2 hours, and meets the
Level 4			0.0	requirements of the National Building Code.
Level 5			0.0	
Level 6			0.0	
Level 7			0.0	
Level 8			0.0	
Total	219.3		219.3	

Total Effective Floor Area 219.3 m²

Step C. Therefore RFF = 3,000 L/min (rounded to nearest 1000 L/min)

Step D. The required fire flow may be reduced by as much as -25% for occupancies having contents with very low fire hazard or may be increased by up to 25% surcharge for occupancies having a high fire hazard.

Type of Occupancy	Adjustment Factor	Occupancy and Contents Adjustment Factor			
Medical Office	Combustible	0%	Non-Combustible	-25%	
			Limited Combustible	-15%	
	0 L/min surcharge		Combustible	0%	
			Free Burning	15%	
RFF =	3,000 L/min (not rounded)		Rapid Burning	25%	

Step E. Sprinklers - The required fire flow may be reduced by up to 50% for complete automatic sprinkler protection depending upon adequacy of system. Actual Possible Reduction Yes/No/Unknown Reduction Available Provided Automatic sprinkler protection designed and installed in accordance with NFPA 13? No -30% 0% Water supply is standard for both the system and Fire Department hose lines? -10% Unknown 0% Fully supervised system? -10% 0% *Reduction available assumes complete building coverage Total Reduction % 0% (reduction) *30% reduction typical for building requiring sprinkler system Total Reduced Flow 0 L/min (reduction, not rounded) Step F. Exposure - A percentage of water for the exposures should be added to the required fire flow for the subject building to provide adequate flow rates for hose streams used to reduce the spreading of fire from the subject building to exposed risks. The required fire flow of a subject building may be increased depending on the severity of exposed risks to the subject building and the distance between the exposed risks and the subject building. This charge considers the usage of water supplies to prevent exposed risks from igniting or being damaged during a major fire incident in the subject building. **Separation Distance Maximum Exposure** *If a vertical fire wall is properly constructed and Adjustment Charge has a rating of no less than 2 hours, then the boundary can be treated as protected with no exposure charge 0 to 3m 25% 3.1 to 10m 20% *The maximum exposure adjustment charge to be 10.1 to 20m 15% applied to a subject building is 75% 20.1 to 30m 10% Greater than 30m 0% **Exposed buildings** Name Distance (m) Surcharge Adjacent Dwelling North >30 0% 0 Adjacent Dwelling 20.6 10% 300 East South Adjacent Dwelling 7.8 20% 600 West Adjacent Dwelling >30 0 900 L/min Surcharge (not rounded) Step G. Final Required Fire Flow Step D - Occupancy Adjusted Fire Flow Demand 3,000 L/min Step E - Sprinkler (Reduction) 0 L/min Step F - Exposure Charge 900 L/min 3,900 L/min Final Required Fire Flow: 4,000 1000L/min) 66.7 L/s or 1,057 USGPM **Determine Required Fire Storage Volume** Flow from above 4,000 L/min Refer to Table 1 for Duration Required duration 1.50 hours Therefore: 360,000 Litres or 360 m³ is the required fire storage volume. Table 1 - FUS 2020 **Required Duration of Fire Flow** Flow Required Duration L/min (hours) 2,000 or I 2000 1.0 3,000 1.25 4.000 1.5 5,000 1.75 6,000 2.0 8.000 20 10.000 2.0 12,000 2.5 36.000 8.5 38,000 9.0 40,000 ar 40,000 9.5 *Interpolate for intermediate figures

APPENDIX C

Sanitary Demand Calculations



File: 2361-6530
Date: July 8, 2024
By: DK/GC
Check By: GC/JK

629 Hurontario Street - Existing Sanitary Demand

Developed Site Area 0.10 ha

Number of Residential Units and Land Usage

1) Single Residential
2) Commercial Area
2) Commercial Area
3 units
6 m²

Person Per Residential Unit

1) Single Residential (Per Town Standards) 2.9 persons/unit

Total Residential Population 3 Persons

Unit Sewage flows

Residential (Per Town Standards)

Commercial (Per Town Standards)

260 L/C-day
21.6 m³/ha/d

Infiltration (Per Town Standards) 0.23 L/s/ha

<u>Total Design Sewage Flows</u>

Infiltration/Inflow Residential 0.02 L/sec Average Daily Residential Flow 0.009 L/sec

Residential Peak Factor (Harmon Formula) 4.5

Total Peak Daily Flow 0.062 L/sec



File: 2361-6530 Date: July 8, 2024 By: DK/GC Check By: GC/JK

<u>629 Hurontario Street - Proposed Sanitary Demand</u>

Developed Site Area 0.10 ha

Number of Residential Units and Land Usage

1) Single Residential Units 2) Commercial Area 189 m²

Person Per Residential Unit

1) Single Residential (Per Town Standards) 2.9 persons/unit

Total Population (four practioners and one employee) 5 Persons

Unit Sewage flows

Residential (Per Town Standards) 260 L/C-day

Commercial (Doctor's Office, Per OBC 8.2.1.3) 275 L/practitioner/d

75 L/employee per 8 hr shift/day

Infiltration (Per Town Standards) 0.23 L/s/ha

Total Design Sewage Flows

0.023 L/sec Infiltration/Inflow Residential 0.014 L/sec


Average Daily Flow

Peak Factor (Harmon Formula) 4.4

Total Peak Daily Flow 0.083 L/sec

APPENDIX D

Topographic Survey (Van Harten Surveying Inc., December 2022)



APPENDIX E

Stormwater Management Calculations (Modified Rational Method Calculations, Stage Storage Discharge, Pipe Volume Calculations)



PROJECT: 629 Hurontario Street PROJECT No.: 2361-6530 DATE: 2023-06-19


DESIGN: D.K. CHECK: G.C.

Modified Rational Method Storage Sizing - 5-Year

Peak Flow $\overline{Q_{post} = 0.0028 \cdot C_{post} \cdot i_{(T_d)} \cdot A}$

 $\frac{\text{Intensity}}{i_{(Td)} = A / (T+B) ^c}$

Storage $S_d = Q_{post} \cdot T_d - Q_{pre} (T_d + T_c) / 2$



Pre-Development Scenario Data					
Inputs	Inputs				
IDF Location	Collingwood	Intensity (mm/hr):	102.27		
Return Period	5 yr				
Time of Concentration (min)	10				
Coeff A	1135.4				
Coeff B	7.5				
Coeff C	0.841				
Runoff Coeff (Unadjusted)	0.48	Flow (m ³ /s)	0.018		
Runoff Coefficient (Adjusted)	0.48				
Area (ha)	0.133				

Post-Development Scenario Data						
Inputs		Outputs				
IDF Location	Collingwood	Intensity (mm/hr):	102.27			
Return Period	5 yr					
Time of Concentration (min)	10					
Coeff A	1135.4					
Coeff B	7.5					
Coeff C	0.841					
Runoff Coeff (unadjusted)	0.57	Uncont. Flow (m³/s)	0.022			
Runoff Coefficient (Adjusted)	0.57					
Area (ha)	0.133					

Target Flow (m³/s) 0.018

REQUIRED STORAGE VOLUME:

2.1


S	Storage Volume Determination (Detailed)					
T _d	i	T _d	Q _{Uncont}	S _d		
min	mm/hr	sec	m³/s	m³		
0	208.56	0	0.045	-5.5		
1	187.72	60	0.040	-3.7		
2	170.96	120	0.037	-2.3		
3	157.16	180	0.034	-1.1		
4	145.58	240	0.031	-0.3		
5	135.72	300	0.029	0.4		
6	127.21	360	0.027	0.9		
7	119.79	420	0.026	1.3		
8	113.26	480	0.024	1.7		
9	107.46	540	0.023	1.9		
10	102.27	600	0.022	2.0		
15	82.79	900	0.018	2.1		
20	69.93	1200	0.015	1.3		
25	60.77	1500	0.013	0.1		
30	53.88	1800	0.012	-1.4		
35	48.49	2100	0.010	-3.1		
40	44.16	2400	0.009	-5.0		
45	40.60	2700	0.009	-7.0		
50	37.61	3000	0.008	-9.1		
55	35.06	3300	0.007	-11.2		
60	32.86	3600	0.007	-13.4		
65	30.95	3900	0.007	-15.7		
70	29.26	4200	0.006	-18.0		
75	27.76	4500	0.006	-20.3		
80	26.42	4800	0.006	-22.7		
85	25.21	5100	0.005	-25.1		



PROJECT: 629 Hurontario Street

PROJECT No.: 2361-6530 DATE: 2024.06.27 DESIGN: D.K. CHECK: J.K.


Modified Rational Method Storage Sizing - 100-Year



 $\frac{\text{Intensity}}{i_{(T^d)} = A / (T+B) ^c}$



Storage $S_d = Q_{post} \cdot T_d - Q_{pre} (T_d + T_c) / 2$



Pre-Development Scenario Data											
Inputs		Outputs									
IDF Location	Collingwood	Intensity (mm/hr):	168.45								
Return Period	100 yr										
Time of Concentration (min)	10										
Coeff A	2193.1										
Coeff B	9.04										
Coeff C	0.871										
Runoff Coeff (Unadjusted)	0.48	Flow (m ³ /s)	0.030								
Runoff Coefficient (Adjusted)	0.48										
Area (ha)	0.133										

Post-Development Scenario Data										
Inputs	Inputs									
IDF Location	Collingwood	Intensity (mm/hr):	168.45							
Return Period	100 yr									
Time of Concentration (min)	10									
Coeff A	2193.1									
Coeff B	9.04									
Coeff C	0.871									
Runoff Coeff (unadjusted)	0.57	Uncont. Flow (m³/s)	0.036							
Runoff Coefficient (Adjusted)	0.57									
Area (ha)	0.133									

Target Flow (m³/s) 0.018

REQUIRED STORAGE VOLUME:

13.7

9	itorage Volume De	termination (Detailed)	
T _d	i	T _d	Q _{Uncont}	Sd
min	mm/hr	sec	m³/s	m³
0	322.28	0	0.069	-5.4
1	294.14	60	0.063	-2.2
2	270.79	120	0.058	0.5
3	251.09	180	0.054	2.6
4	234.23	240	0.050	4.4
5	219.64	300	0.047	6.0
6	206.86	360	0.044	7.3
7	195.58	420	0.042	8.4
8	185.54	480	0.040	9.3
9	176.55	540	0.038	10.1
10	168.45	600	0.036	10.8
15	137.49	900	0.029	12.9
20	116.62	1200	0.025	13.7
25	101.55	1500	0.022	13.6
30	90.13	1800	0.019	13.1
35	81.15	2100	0.017	12.1
40	73.89	2400	0.016	10.9
45	67.90	2700	0.015	9.5
50	62.86	3000	0.013	7.9
55	58.57	3300	0.013	6.2
60	54.85	3600	0.012	4.4
65	51.61	3900	0.011	2.5
70	48.76	4200	0.010	0.5
75	46.22	4500	0.010	-1.5
80	43.95	4800	0.009	-3.5
85	41.91	5100	0.009	-5.6



Project: 629 Hurontario Street **Project No.:** 2361-6530 **By:** JK **Date:** 2025-02-11

629 HURONTARIO STREET - SUPERPIPE STORAGE CALCULATIONS

	Storm Sewer Network Parameters													
Sewer # From To Length (m) Slope (%) US Invert DS Invert Size (mm)														
#1	DICB1	DCBMH2	10.90	0.50	187.770	187.720	250							
#2	DICB2	DCBMH2	11.10	0.50	187.790	187.725	250							
#3	DCBMH2	MH3	8.70	0.40	187.670	187.640	300							

Sewer #												Wate	er Depth at US Inv	vert of Sewer (m) for each Storm	Event					
Event	1	2	3	4	5	6	7	8	9	Ponding HWL	1	2	3	4	5	6	7	8	9	Ponding HWL	
Water Level (m)	187.64	187.80	187.96	188.12	188.28	188.44	188.60	188.76	188.92	188.94	187.64	187.80	187.96	188.12	188.28	188.44	188.60	188.76	188.92	188.94	
#1	0.00	0.07	0.23	0.39	0.55	0.71	0.87	1.03	1.19	1.22	0.00	0.07	0.23	0.39	0.55	0.71	0.87	1.03	1.19	1.22	
#2	0.00	0.07	0.24	0.40	0.56	0.72	0.88	1.04	1.20	1.22	0.00	0.08	0.24	0.40	0.56	0.72	0.88	1.04	1.20	1.22	
#3	0.00	0.16	0.32	0.48	0.64	0.80	0.96	1.12	1.28	1.30	0.00	0.13	0.29	0.45	0.61	0.77	0.93	1.09	1.25	1.27	

Note: Water Depth in each sewer is calculated as Storm Event Water Elevation - Invert Elevation (DS or US). In cases where the sewer invert is above the storm water elevation, the water depth is equal to 0.

Sewer #		Water-Filled Area at DS Invert of Sewer (m²) for each Storm Event										Water-F	illed Area at US	Invert of Sewer (m²) for each Stor	m Event					
Event	1	2	3	4	5	6	7	8	9	Ponding HWL	1	2	3	4	5	6	7	8	9	Ponding HWL	
Water Level (m)	187.64	187.80	187.96	188.12	188.28	188.44	188.60	188.76	188.92	188.94	187.64	187.80	187.96	188.12	188.28	188.44	188.60	188.76	188.92	188.94	
#1	0.00	0.0124	0.0479	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.00	0.0124	0.0479	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	
#2	0.00	0.0124	0.0484	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.00	0.0135	0.0484	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	0.0491	
#3	0.00	0.0383	0.0707	0.0707	0.0707	0.0707	0.0707	0.0707	0.0707	0.0707	0.00	0.0294	0.0700	0.0707	0.0707	0.0707	0.0707	0.0707	0.0707	0.0707	

Note: Water-Filled Areas are calculated using the following equation, where R = Sewer radius (m) and h = Water depth in sewer (m): In cases where the sewer cross-section is full, the Water-Filled Area is calculated as π^*R^2 .

Area =
$$R^2 \cos^{-1} \left(\frac{R-h}{R} \right) - (R-h) \sqrt{2Rh-h^2}$$

Sewer #		Storage Volume in Sewer (m³) for each Storm Event										
Event	1	1 2 3 4 5 6 7 8 9										
Water Level (m	n) 187.64	187.80	187.96	188.12	188.28	188.44	188.60	188.76	188.92	188.94		
#1	0.00	0.14	0.52	0.54	0.54	0.54	0.54	0.54	0.54	0.54		
#2	0.00	0.14	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54		
#3	0.00	0.29	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61		
TOTAL	0.0	0.6	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7		

Note: Storage Volume is calculated as the Sewer Length multiplied by the average of the DS and US Water-Filled Areas. Total Storage in the system is calculated as the sum of the storage volume in each sewer.



Project: 629 Hurontario Street

Project No.: 2361-6530

Design by: JK

Date: 2025-02-11

629 Hurontario Street Supersize Pipe Storage Data

Storm Structure Storage Data										
CB Structures	Area	T/G Elevation	Inv Elev	Volume						
	(m²)	(m)	(m)	(m³)						
DICB1	0.72	188.76	187.77	0.71						
DICB2	0.72	188.69	187.79	0.65						
DCBMH2	1.96									
To	3.3									

	Pipe Storage Data											
From MH# To MH# Length Diameter Storage Vol												
	(m³)											
DICB1	DCBMH2	10.9	250	0.54								
DICB2	DCBMH2	11.1	250	0.54								
DCBMH2	DCBMH2 MH3 8.7 300											
1	Total Pipe Storage (m³)											

Stage-Storage-Discharge Table - External Conveyance System

187.61 m Orifice Diameter 0.085 m

Supersize Pipe Stage-Storage-Discharge Data Water Pipe #1 Pipe #2 Pipe #3 Depth Orifice A Storage Water Level Storage Storage Total DICB1 DICB2 DCBMH2 Ponding Total Discharge Comments above (DICB2 to (DCBMH2 Storage Discharge Elevation (DICB1 to Lower ICD DCBMH2) DCBMH2) to MH3) Invert (m³/s) (m) (m) (m³) (m³) (m³) (m³) (m³) (m³) (m³) (m³) (m^3/s) 187.64 0.00 0.00 0.00 0.00 0.000 0.000 0.00 0.00 0.00 0.00 0.0 187.80 0.16 0.14 0.29 0.34 0.02 0.01 0.14 0.00 0.9 0.006 0.006 187.96 0.32 0.52 0.61 0.70 0.14 0.12 0.42 0.00 2.5 0.008 0.008 188.12 0.48 0.54 0.61 0.71 0.25 0.24 0.71 0.00 3.1 0.011 0.011 188.28 0.64 0.54 0.61 0.71 0.37 0.35 0.99 0.00 3.6 0.012 0.012 188.44 0.80 0.54 0.61 0.71 0.48 0.47 1.27 0.00 4.1 0.014 0.014 0.96 0.71 0.60 0.58 1.56 0.00 4.6 0.015 0.015 188.60 0.54 0.61 1.12 0.54 0.61 0.71 0.65 1.84 0.017 188.76 0.71 0.00 5.1 0.017 188.92 1.28 0.54 0.61 0.71 0.71 0.65 1.96 5.30 10.5 0.018 0.018 0.71 0.65 0.018 188.94 1.30 0.61 0.71 1.96 10.70 15.9 0.018 0.54

**Please refer to 2024.06.27 Pipe Volume Calculations Spreadsheet for Storage Details

APPENDIX F

Oil/Grit Separator Sizing Report



CDS ESTIMATED NET ANNUAL SOLIDS LOAD REDUCTION BASED ON THE RATIONAL RAINFALL METHOD BASED ON A FINE PARTICLE SIZE DISTRIBUTION



Project Name: 629 Hurontario St Engineer: Crozier & Associates Consulting Eng

Location: Collingwood, ON Contact: Jonathon Kerschbaumer

OGS #: OGS Report Date: 4-Dec-24

Area 0.07 ha Rainfall Station # 203
Weighted C 0.9 Particle Size Distribution FINE
CDS Model 2015-4 CDS Treatment Capacity 20 l/s

Rainfall Intensity ¹ (mm/hr)	Percent Rainfall Volume ¹	Cumulative Rainfall Volume	Total Flowrate (I/s)	Treated Flowrate (I/s)	Operating Rate (%)	Removal Efficiency (%)	Incremental Removal (%)
0.5	8.7%	8.7%	0.1	0.1	0.4	98.7	8.6
1.0	10.8%	19.6%	0.2	0.2	0.9	98.6	10.7
1.5	9.5%	29.0%	0.3	0.3	1.3	98.5	9.3
2.0	8.4%	37.4%	0.4	0.4	1.8	98.4	8.3
2.5	6.8%	44.2%	0.4	0.4	2.2	98.2	6.7
3.0	5.6%	49.8%	0.5	0.5	2.7	98.1	5.5
3.5	5.1%	54.9%	0.6	0.6	3.1	98.0	5.0
4.0	4.9%	59.8%	0.7	0.7	3.5	97.8	4.8
4.5	4.1%	63.9%	0.8	0.8	4.0	97.7	4.0
5.0	3.5%	67.4%	0.9	0.9	4.4	97.6	3.4
6.0	4.9%	72.3%	1.1	1.1	5.3	97.3	4.8
7.0	4.0%	76.3%	1.2	1.2	6.2	97.1	3.9
8.0	3.2%	79.5%	1.4	1.4	7.1	96.8	3.1
9.0	2.2%	81.7%	1.6	1.6	8.0	96.6	2.1
10.0	2.0%	83.7%	1.8	1.8	8.8	96.3	1.9
15.0	8.2%	91.9%	2.6	2.6	13.3	95.1	7.8
20.0	3.4%	95.2%	3.5	3.5	17.7	93.8	3.2
25.0	2.5%	97.7%	4.4	4.4	22.1	92.5	2.3
30.0	1.4%	99.1%	5.3	5.3	26.5	91.3	1.3
35.0	0.3%	99.4%	6.1	6.1	30.9	90.0	0.2
40.0	0.6%	100.0%	7.0	7.0	35.3	88.7	0.5
45.0	0.0%	100.0%	7.9	7.9	39.8	87.5	0.0
50.0	0.0%	100.0%	8.8	8.8	44.2	86.2	0.0
							97.3

Removal Efficiency Adjustment² =


Predicted Net Annual Load Removal Efficiency =
Predicted % Annual Rainfall Treated =

6.5% **90.8% 100.0%**

1 - Based on 27 years of hourly rainfall data from Canadian Station 6110557, Barrie ON

- 2 Reduction due to use of 60-minute data for a site that has a time of concentration less than 30-minutes.
- 3 CDS Efficiency based on testing conducted at the University of Central Florida
- 4 CDS design flowrate and scaling based on standard manufacturer model & product specifications

PLAN VIEW B-B





CDS PMSU2015-4-C DESIGN NOTES

THE STANDARD CDS PMSU2015-4-C CONFIGURATION IS SHOWN. ALTERNATE CONFIGURATIONS ARE AVAILABLE AND ARE LISTED BELOW. SOME CONFIGURATIONS MAY BE COMBINED TO SUIT SITE REQUIREMENTS.

CONFIGURATION DESCRIPTION

GRATED INLET ONLY (NO INLET PIPE)


GRATED INLET WITH INLET PIPE OR PIPES

CURB INLET ONLY (NO INLET PIPE)

CURB INLET WITH INLET PIPE OR PIPES

CUSTOMIZABLE SUMP DEPTH AVAILABLE

ANTI-FLOTATION DESIGN AVAILABLE UPON REQUEST



FRAME AND COVER (DIAMETER VARIES) N.T.S.

SITE SPECIFIC DATA REQUIREMENTS										
STRUCTURE ID										
WATER QUALITY	FLOW RAT	E (CF	S OR L/s)		*					
PEAK FLOW RAT	E (CFS OR	L/s)			*					
RETURN PERIOD	OF PEAK F	LOW	(YRS)		*					
SCREEN APERTU	JRE (2400 C	R 470	00)		*					
PIPE DATA:	I.E.	MA	TERIAL	D	IAMETER					
INLET PIPE 1	*		*		*					
INLET PIPE 2	*		*		*					
OUTLET PIPE	*		*		*					
RIM ELEVATION					*					
ANTI-FLOTATION	BALLAST		WIDTH		HEIGHT					
* *										
NOTES/SPECIAL REQUIREMENTS:										
* PER ENGINEER OF RECORD										

GENERAL NOTES

- 1. CONTECH TO PROVIDE ALL MATERIALS UNLESS NOTED OTHERWISE.
- 2. DIMENSIONS MARKED WITH () ARE REFERENCE DIMENSIONS. ACTUAL DIMENSIONS MAY VARY.
- 3. FOR FABRICATION DRAWINGS WITH DETAILED STRUCTURE DIMENSIONS AND WEIGHTS, PLEASE CONTACT YOUR CONTECH ENGINEERED SOLUTIONS LLC REPRESENTATIVE. www.contechES.com
- 4. CDS WATER QUALITY STRUCTURE SHALL BE IN ACCORDANCE WITH ALL DESIGN DATA AND INFORMATION CONTAINED IN THIS DRAWING.
- 5. STRUCTURE SHALL MEET AASHTO HS20 AND CASTINGS SHALL MEET HS20 (AASHTO M 306) LOAD RATING, ASSUMING GROUNDWATER ELEVATION AT, OR BELOW, THE OUTLET PIPE INVERT ELEVATION. ENGINEER OF RECORD TO CONFIRM ACTUAL GROUNDWATER ELEVATION.
- 6. PVC HYDRAULIC SHEAR PLATE IS PLACED ON SHELF AT BOTTOM OF SCREEN CYLINDER. REMOVE AND REPLACE AS NECESSARY DURING MAINTENANCE CLEANING.

INSTALLATION NOTES

- A. ANY SUB-BASE, BACKFILL DEPTH, AND/OR ANTI-FLOTATION PROVISIONS ARE SITE-SPECIFIC DESIGN CONSIDERATIONS AND SHALL BE SPECIFIED BY ENGINEER OF RECORD.
- B. CONTRACTOR TO PROVIDE EQUIPMENT WITH SUFFICIENT LIFTING AND REACH CAPACITY TO LIFT AND SET THE CDS MANHOLE STRUCTURE (LIFTING CLUTCHES PROVIDED).
- C. CONTRACTOR TO ADD JOINT SEALANT BETWEEN ALL STRUCTURE SECTIONS, AND ASSEMBLE STRUCTURE.
- D. CONTRACTOR TO PROVIDE, INSTALL, AND GROUT PIPES. MATCH PIPE INVERTS WITH ELEVATIONS SHOWN.
- E. CONTRACTOR TO TAKE APPROPRIATE MEASURES TO ASSURE UNIT IS WATER TIGHT, HOLDING WATER TO FLOWLINE INVERT MINIMUM. IT IS SUGGESTED THAT ALL JOINTS BELOW PIPE INVERTS ARE GROUTED.



CDS PMSU2015-4-C INLINE CDS STANDARD DETAIL

FIGURES

Figure 1: Site Location Plan

Figure 2: Site Plan

Figure 3: Pre-Development Drainage Plan

Figure 4: Post-Development Drainage Plan



= SUBJECT LANDS

629 HURONTARIO STREET


Drawing


SITE LOCATION PLAN


TOWN OF COLLINGWOOD



2361-7140 G.C. Prowing FIG. 1 N.T.S. Date 08/23/2023









DRAWINGS


Drawing C102: Removals and Erosion & Sediment Control Plan


Drawing C103: Servicing Plan
Drawing C104: Grading Plan


Drawing C105 - C106: Standard Notes & Details














CONSTRUCTION NOTES

A) GENERAL — CONSTRUCTION ALL WORK TO BE CARRIED OUT IN ACCORDANCE WITH TOWN OF COLLINGWOOD STANDARDS (2007), OPSD AND OPSS. WHERE CONFLICT OCCURS, TOWN

OF COLLINGWOOD STANDARDS (2007) TO GOVERN. TRENCH BACKFILL (OPSD 802.010 & 802.013) TO BE SELECT NATIVE MATERIAL OR IMPORTED SELECT SUBGRADE TO OPSS 1010. BACKFILL TO BE

PLACED IN MAXIMUM 200mm THICK LIFTS AND COMPACTED TO 95% OF THE MATERIAL'S STANDARD PROCTOR MAXIMUM DRY DENSITY (SPMDD). PIPE COVER AND BEDDING TO BE GRANULAR 'A'. MINIMUM 150mm DEPTH COMPACTED TO A MINIMUM 95% SPMDD.

ALL TOPSOIL AND EARTH EXCAVATION TO BE STOCK PILED OR REMOVED TO AN APPROVED SITE AS DIRECTED BY ENGINEER. . THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED LAYOUT OF THE WORK. THE OWNER'S ENGINEER WILL CONFIRM ALL BENCH MARK

ELEVATIONS AND HORIZONTAL ALIGNMENT FOR THE CONTRACTOR. ALL PROPERTY BARS TO BE PRESERVED AND REPLACED BY O.L.S. AT CONTRACTOR'S EXPENSE IF REMOVED DURING CONSTRUCTION.

THE CONTRACTOR SHALL MAKE HIS OWN ARRANGEMENTS FOR THE SUPPLY OF TEMPORARY WATER AND POWER. DEWATERING TO BE CARRIED OUT IN ACCORDANCE WITH OPSS-517 AND 518 TO MAINTAIN ALL TRENCHES IN A DRY CONDITION. ALL ENGINE DRIVEN PUMPS TO BE ADEQUATELY SILENCED, SUITABLE FOR OPERATION IN A RESIDENTIAL DISTRICT.

DISTURBED AREAS OUTSIDE THE PROJECT LIMITS TO BE REINSTATED TO PREVIOUS CONDITION OR BETTER. THE CONTRACTOR IS RESPONSIBLE TO NOTIFY ALL UTILITY COMPANIES PRIOR TO COMMENCING WORK AND CO-ORDINATE CONSTRUCTION ACCORDINGLY. 12. ALL ROCK EXCAVATION PER OPSS-206. 13. ALL EXCAVATION MUST BE CARRIED OUT IN FULL COMPLIANCE WITH MOST RECENT GUIDELINES OF OHSA.

B) PARKING LOT AND ENTRANCES

SUBGRADE TO BE COMPACTED TO A MINIMUM DRY DENSITY OF AT LEAST 95% SPMDD.

SUBGRADE TO BE PROOF ROLLED AND CERTIFIED PRIOR TO PLACING GRANULAR 'B'. GRANULAR 'A' AND 'B' BASE MATERIALS TO BE COMPACTED TO 100% OF THE MATERIAL'S RESPECTIVE SPMDD AND PLACED IN MAX. 150mm LIFTS.

REFER TO PAVEMENT STRUCTURE DETAILS FOR INTERNAL ROADWAY, DRIVEWAYS AND PARKING AREAS. SELECT SUBGRADE MATERIAL, OR IMPORTED GRANULAR MATERIAL APPROVED BY THE ENGINEER, COMPACTED TO 98% SPMDD TO BE USED AS FILL IN

ALL AREAS WHERE PROPOSED PIPE INVERTS ARE HIGHER THAN EXISTING GRADE OR AS INSTRUCTED BY THE ENGINEER. ALL GRANULARS AND ASPHALT MATERIALS PLACEMENT TO BE IN ACCORDANCE WITH OPSS 314 AND OPSS 310. JOINTS WITH EXISTING ASPHALT TO BE SAW CUT STRAIGHT PRIOR TO PLACING NEW ASPHALT AND TACK COAT APPLIED TO EXISTING ASPHALT.

CONCRETE CURB TO OPSD 600.110 AND OPSS 353. CONCRETE CURB AND GUTTER TO OPSD 600.040 AND OPSS 353. CONCRETE SIDEWALK TO OPSD 310.010, 310.030, 350.010 AND OPSS 351. SUBBASE TO CONSIST OF MIN. 150mm OF GRANULAR 'A' UNLESS THROUGH

DRIVEWAYS.

C) STORM SEWERS

MH AND CBMH TO OPSD - 701.012, 701.030, 701.100, 704.010, C/W SUMP UNLESS NOTED OTHERWISE.

STEPS TO OPSD 405,010. M.H. FRAMES AND GRATES TO OPSD - 401.01 OPEN COVER. CB'S TO OPSD - 705.010.

CB AND CBMH FRAMES AND GRATES TO OPSD - 400.020

PIPE SUPPORT AT MH'S, CB'S, CBMH'S AND DCBMH'S TO DCBMH CAP OPSD - 703.021.

PROTECTION DURING CONSTRUCTION TO OPSD - 808.010. BACKFILL AND EMBEDMENT TO OPSD - 802.010 (FLEXIBLE PIPE) GRANULAR 'A' EMBEDMENT OR OPSD - 802.030, 802.031 AND 802.032 (RIGID PIPE) GRANULAR 'A' FMBFDMFNT

BACKFILL AND EMBEDMENT MATERIAL TO BE COMPACTED TO A DRY DENSITY OF AT LEAST 95% OF THE MATERIAL'S SPMDD. 10. STORM SEWERS SHALL BE PVC SMOOTH WALL RIBBED PIPE MINIMUM STIFFNESS (320kPa). ALL PIPE TO BE JOINED WITH A GASKETTED BELL AND

SPIGOT SYSTEM. CATCHBASIN LEADS TO BE 250mmø PVC PIPE (SDR-35).

D) GENERAL - EROSION & SEDIMENT CONTROLS ALL SEDIMENT AND EROSION CONTROL MEASURES SHALL BE INSTALLED PRIOR TO THE COMMENCEMENT OF CONSTRUCTION AND SHALL REMAIN IN PLACE UNTIL ALL DISTURBED AREAS HAVE BEEN STABILIZED. SEDIMENT AND EROSION.

THE CONTRACTOR MAY CONSIDER ALTERNATIVE SEDIMENT AND EROSION CONTROL MEASURES. SUCH MEASURES MUST BE PRESENTED IN WRITING FOR APPROVAL OF THE CONTRACT ADMINISTRATOR AND TOWN STAFF THE CONTRACTOR SHALL HAVE MATERIALS AVAILABLE ON-SITE TO REPAIR SEDIMENT AND EROSION CONTROL MEASURES IN THE EVENT OF

UNFORESEEN CONDITIONS: HIGHWATER, EXTREME RAINFALL EVENTS, ETC. CONTRACTOR TO ENSURE POSITIVE DRAINAGE THROUGH SITE SUCH THAT NO UPSTREAM OR DOWNSTREAM IMPACT OCCURS DURING CONSTRUCTION

THE CONTRACTOR WILL BE RESPONSIBLE TO CLEAN ALL ADJACENT ROADWAYS AS REQUIRED OR AS DIRECTED BY SITE ENGINEER OR TOWN STAFF.


E) MAINTENANCE & OPERATION OF SEDIMENT CONTROLS


SILT FENCE TO BE INSTALLED ALONG PROPERTY LINE AND ALONG LIMITS OF PROTECTED AREAS.


SILT FENCE MUST BE INSPECTED WEEKLY FOR RIPS OR TEARS, BROKEN STAKES, BLOW-OUTS AND ACCUMULATION OF SEDIMENT. SILT FENCE MUST BE INSPECTED IMMEDIATELY AFTER EVERY RAIN STORM EVENT OR AS DIRECTED BY SITE ENGINEER. SEDIMENT DEPOSITS MUST BE REMOVED FROM SILT FENCE WHEN ACCUMULATION REACHES 50% OF THE HEIGHT OF THE FENCE.

ALL SILT FENCES MUST BE REMOVED ONLY WHEN THE ENTIRE SITE IS STABILIZED AND AS DIRECTED BY THE SITE ENGINEER.

INSTALL SILT SACKS ON EXISTING CATCH BASINS ALONG COLLINS STREET.







THIS DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & TEMPORARY BENCHMARKS ASSOCIATES INC. AND THE MODIFICATION AND/OR REPRODUCTION OF TBM#1-CUT CROSS IN SIDEWALK - ELEV. 188.74m ANY PART OF THIS DRAWING IS STRICTLY PROHIBITED WITHOUT WRITTEN AUTHORIZATION FROM THIS OFFICE. THE DIGITAL FILES CONTAIN INTELLECTUAL AND DIGITAL DATA PROPERTY LEGAL AND TOPOGRAPHIC SURVEY BY VAN HARTEN SURVEYING INC. THAT IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC. (DECEMBER 5, 2022) THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND DATUMS ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS TO C.F. CROZIER & ASSOCIATES INC. PRIOR TO CONSTRUCTION THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS PROJECT.

ALL EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD BY

THE CONTRACTOR PRIOR TO CONSTRUCTION.

DO NOT SCALE DRAWINGS.

DATE: YYYY/MM/DD SSUED FOR 1st SUBMISSION (SPA) 2024/07/26 SSUED FOR 2ND SUBMISSION (SPA) 2024/10/18 SSUED FOR 3RD SUBMISSION (SPA) 2025/01/07 E-ISSUED FOR 3RD SUBMISSION (SPA) 2025/01/22



G.F. COOPER

100532614

Jan. 22, 2025





629 HURONTARIO STREET TOWN OF COLLINGWOOD





STANDARD NOTES AND DETAILS


2361-7140

















THIS DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC. AND THE MODIFICATION AND/OR REPRODUCTION OF ANY PART OF THIS DRAWING IS STRICTLY PROHIBITED WITHOUT WRITTEN AUTHORIZATION FROM THIS OFFICE. THE DIGITAL FILES CONTAIN INTELLECTUAL AND DIGITAL DATA PROPERTY THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND DATUMS

THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH

ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS PROJECT. ALL EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD BY

CROZIER & ASSOCIATES INC. PRIOR TO CONSTRUCTION.

THE CONTRACTOR PRIOR TO CONSTRUCTION.

. DO NOT SCALE DRAWINGS.

TBM#1-CUT CROSS IN SIDEWALK - ELEV. 188.74m LEGAL AND TOPOGRAPHIC SURVEY BY VAN HARTEN SURVEYING INC. THAT IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC. (DECEMBER 5, 2022) ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS TO C.F.

TEMPORARY BENCHMARKS

No.	ISSUE	DATE: YYYY/MM/DD	Engine
1	ISSUED FOR 1st SUBMISSION (SPA)	2024/07/26	/
2	ISSUED FOR 2ND SUBMISSION (SPA)	2024/10/18	15
3	ISSUED FOR 3RD SUBMISSION (SPA)	2025/01/07	CEA
4	RE-ISSUED FOR 3RD SUBMISSION (SPA)	2025/01/22	7
			\ .
			1
			•





629 HURONTARIO STREET TOWN OF COLLINGWOOD



STANDARD NOTES AND DETAILS

Drawn By	M.R.	Design By	D.K./G.C.	Project	2361-7140
Check By	G.C.	Check By	J.K.	Drawing	C106