

tathameng.com



File 123019

October 19, 2023

Heather McGinnity
Manager, Environmental Services
Town of Collingwood
97 Hurontario Street
Collingwood, Ontario L9Y 325
HMcGinnity@collingwood.ca

Re: 2-Storey Office and Restaurant Building, 498 Hume Street, Town of Collingwood

Addendum to Servicing Report

Dear Heather:

Tatham Engineering Limited has been retained by Dunn Capital Corporation to prepare an update to the water and sanitary servicing strategy for 498 Hume Street, in support of a site plan amendment application for a proposed 2-storey restaurant and office on building pad 1. This letter will serve as an addendum to the Servicing and Stormwater Management Report dated February 2018 prepared by C.F. Crozier & Associates Inc.

BACKGROUND

Site plan approval was granted for 500 Hume Street in 2018 for three buildings: a 2-storey office space (Pad 1), a 3-storey office building (Pad 2), and a Holiday Inn hotel (Pad 3). To date, the Holiday Inn has been constructed, and construction is underway on a 4-storey business type hotel on building pad 2. The change of use for building pad 2 was approved following an addendum dated August 2022 to the 2018 Servicing Report.

A 2-storey building, in which 1 storey will be used for a restaurant and the other floor for office space, is now proposed for building pad 1. The water and sanitary servicing requirements need to be updated to reflect the current standards and the proposed use. There are no updates to the stormwater management and site drainage strategy as the building foundation has already been constructed and the footprint has not changed. No other changes to the existing site plan are proposed.

The site servicing plan drawing dated April 13, 2018, and the building pad 1 elevations drawing are attached. Based on the site servicing plan, the proposed building will have a ground floor area of 475 m² and a gross floor area of 950 m². Approximately 80% of the restaurant floor area (380 m²) will be used for seating. The remaining space will be used for kitchen, staff, waiting area, and washroom space. Using an





occupant load of $1.10 \text{ m}^2/\text{person}$ (as per OBC Table 3.1.17.1), the restaurant will have 346 seats. The other storey will be used for office space.

SANITARY SERVICING

Existing Sanitary Infrastructure

An existing gravity sanitary sewer is located on Raglan Street with a 200 mm diameter sanitary service stub that extends from Raglan Street adjacent to the proposed 2-storey restaurant and office space.

Proposed Sanitary Servicing

A 200 mm diameter sanitary service lateral is proposed to be connected to the existing service stub on the 200 mm diameter sanitary sewer on Raglan Street.

Sanitary Flows

Updated sanitary flows for the proposed building have been calculated based on the Town of Collingwood Development Standards (Town Standards) and the 2017 Ontario Building Code (OBC), as shown in Table 1.

Table 1: Sanitary Design Criteria

DESIGN CRITERIA	DESIGN VALUE	REFERENCE STANDARD
Average Sanitary Sewage Flow: Restaurant	125 L/seat/day	OBC Table 8.2.1.3.B.12.a)
Average Sanitary Sewage Flow: Office Space	75 L/9.3 m² floor space/ day	OBC Table 8.2.1.3.B.15.b)
Peaking Factor	4.5	Town Standards
Peak Inflow and Infiltration Rate	0.23 L/ha/s	Town Standards

The sanitary design flows for the proposed building are calculated as follows:

Average Daily Sanitary Sewage Flow (ADF) = $346 \text{ seats} \times 125 \text{ L/seat/day} + 75 \text{ L/9.3 m}^2 \text{ floor space/day} \times 475 \text{ m}^2$

= 47,080 L/day

 $= 47.08 \text{ m}^3/\text{day} (0.544 \text{ L/s})$

Peak Sanitary Sewage Flow = ADF x Peaking factor + Peak I&I Flow



=
$$(0.544 \text{ L/s} \times 4.5) + (1/3 \times 1.74 \text{ ha} \times 0.23 \text{ L/ha/s})$$

= $2.45 \text{ L/s} + 0.13 \text{ L/s}$
= 2.58 L/s

The sanitary design flows for the originally proposed 2-storey building and the proposed 2-storey restaurant and office space are summarized in Table 2 for comparison.

Table 2: Sanitary Design Flows - Comparison for Building Pad 1

BUILDING PAD 1	AVERAGE DAILY SEWAGE FLOW (m³/day)	PEAK DAILY SEWAGE FLOW (L/s)
Original 2-Storey Building	47.08	2.58
2-Storey Restaurant and Office Space	47.08	2.58

The total sanitary design flows for the three buildings on the site are summarized in Table 3, including the updated flows calculated for building pad 1. Sewage flows for the Holiday Inn were previously calculated in the February 2018 Servicing Report for the site. Sewage flows for building pad 2 were previously calculated in the August 2022 Servicing Report addendum for the site.

Table 3: Sanitary Design Flows - Site Summary

BUILDING	AVERAGE DAILY SEWAGE FLOW (m³/day)	PEAK DAILY SEWAGE FLOW (L/s)
2-Storey Restaurant and Office Space (Pad 1)	47.1	2.6
4-Storey Hotel (Pad 2)	29.3	1.7
Holiday Inn (Pad 3)	23.2	1.2
Total	99.6	5.5

Sanitary Collection, Treatment, and Disposal Capacity

It is our understanding that water and wastewater treatment plant capacity has been allocated for the site in accordance with the Town's Servicing Capacity Allocation Policy, via an exemption from the Town's Interim Control By-Law No. 2021-024 on June 20, 2022.

The total average daily and peak sewage flows for the site remain the same as originally proposed. Therefore, it is expected that the municipal sanitary system remains capable of providing adequate sanitary collection, treatment, and disposal capacity for the site.



WATER SERVICING

Existing Water Infrastructure

Existing 300 mm diameter municipal watermain is located on Raglan Street, west of the site, and on Hume Street, north of the site. A 100 mm stub extends from Raglan Street adjacent to the proposed building. A 200 mm diameter watermain extends from Raglan Street through the site to Hume Street, with hydrants and services to each of the three buildings.

Proposed Water Servicing

The building will be serviced by separate fire and commercial water service lines, with an isolation valve on each, and one backflow prevention device and one water meter located inside the building. A 200 mm diameter fire service connection will be provided to the building from the existing 200 mm diameter watermain running through the site. A 100 mm diameter commercial water service will be provided from the 200 mm fire service. The existing 100 mm stub from Raglan Street will be decommissioned.

Water Demand

Updated water demands for the proposed building have been calculated based on the Town Standards, the 2017 OBC and the 2008 MECP Design Guidelines for Drinking Water Systems (MECP Guidelines), as noted in Table 4.

Table 4: Water Design Criteria

DESIGN CRITERIA	DESIGN VALUE	REFERENCE STANDARD
Average Daily Demand (ADD): Restaurant	125 L/seat/day	OBC Table 8.2.1.3.B.12.a)
Average Sanitary Sewage Flow: Office Space	75 L/9.3 m² floor space/ day	OBC Table 8.2.1.3.B.15.b)
Maximum Daily Factor	2.0	Town Standards
Peak Hour Factor	4.5	Town Standards
Minimum Pressure	40 psi	MECP Guidelines
Recommended Pressure Range	50 - 70 psi	MECP Guidelines

Water demands for the proposed 195 seat restaurant and the office space are calculated as follows. Average day demand is equivalent to the average daily sewage flow calculated above.

Average Day Demand (ADD) = $47.08 \text{ m}^3/\text{day} (0.544 \text{ L/s})$



Maximum Day Demand (MDD) = ADD x Maximum day factor

 $= 47.08 \text{ m}^3/\text{day x } 2.0$

 $= 94.16 \text{ m}^3/\text{day} (1.088 \text{ L/s})$

Peak Hour Demand (PHD) = ADD x Peak hour factor

 $= 0.544 L/s \times 4.5$

= 2.45 L/s

Fire Flow Requirements

Updated fire flow requirements for the proposed building were calculated based on the Fire Underwriter's Survey Guidelines (FUS, 2020), and using the following building design assumptions:

- 2-storey restaurant and office space with a total effective floor area of 950 m².
- Ordinary materials of construction, with non-combustible roofing materials.
- A2 occupancy classification as per OBC Table 3.1.2.1.
- No automatic sprinklers.
- Exposure distances based on the April 13, 2018, site servicing plan drawing prepared by Crozier & Associates Consulting Engineers.

The total required fire flow rate is 8,000 L/min (133 L/s). The FUS fire flow calculations are attached.

The updated design water demands and fire flow requirements for the previously proposed 2-storey building and the proposed restaurant and office space are summarized in Table 5 for comparison. The updated design water demands and fire flow requirements for the three buildings on the site are summarized in Table 6. Water demand and fire flow calculations for building pad 2 and the Holiday Inn were previously provided in the August 2022 Addendum to Servicing Report, and the February 2018 Servicing Report for the site, respectively.

Table 5: Water Demand and Fire Flow - Comparison

BUILDING	ADD (m³/day)	MDD (m³/day)	PHD (L/s)	FIRE FLOW (L/s)
Original 2-Storey Building	47.1	94.2	2.45	133
2-Storey Restaurant and Office Space	47.1	94.2	2.45	133



Table 6: Water Demand and Fire Flow - Site Summary

BUILDING	ADD (m³/day)	MDD (m³/day)	PHD (L/s)	FIRE FLOW (L/s)
2-Storey Restaurant and Office Space (Pad 1)	47.1	94.2	2.5	133
4-Storey Hotel (Pad 2)	29.3	58.5	1.5	183
Holiday Inn (Pad 3)	23.2	46.5	1.2	217
Total	99.6	199.2	5.2	-

Adequacy of Water Supply Capacity, Pressures, and Flow

As noted above, water and wastewater treatment plant capacity has been allocated for the site in accordance with the Town's Servicing Capacity Allocation Policy. For an equivalent single dwelling unit (SDU) conversion factor of 1.334 m³/unit/day maximum demand, the proposed restaurant and office space has an equivalent of 71 SDUs remains the same as originally proposed 2-storey building at 71 SDUs.

The commercial water demand and required fire flow for the proposed 2-storey restaurant and office space remains the same as the originally proposed 2-storey building.

Hydraulic modeling completed for the site and included in the February 2018 Servicing Report, concluded the development will have minimal impact on distribution system pressures. Ground level pressures are expected to range from 57 psi to 60 psi, which is within the preferred range recommended by the MECP (50 psi to 70 psi). At the second-floor elevation (3.66 m above ground), pressures are expected to range from 52 psi to 55 psi, which remains within the MECP's recommended range.

The previous hydraulic modeling also indicated that the proposed watermains are capable of supplying a fire flow of in excess of the 217 L/s required for the Holiday Inn, and therefore greater than the 133 L/s required for the proposed restaurant and office space.

SUMMARY

The sanitary and water servicing requirements for 498 Hume Street have been updated in support of the proposed 2-storey restaurant and office space. The sanitary sewage flows, and water demands for building pad 1 have remained the same. The total sanitary sewage and water requirements for the site remain the same as those proposed in the February 2018 Servicing Report. In addition, the Town has allocated water and wastewater treatment plant capacity for the site in accordance with its Servicing Capacity Allocation Policy on June 20, 2022. Therefore, it is expected that the municipal sanitary and water systems can provide adequate service to the site.



No changes to the sanitary servicing strategy and minor changes to the water servicing strategy are proposed for the site. As previously proposed, building pad 1 will be provided with a 200 mm diameter sanitary service from the existing Raglan Street municipal sewer. A 200 mm diameter fire service and a 100 mm diameter domestic water service will be provided to the building from the existing 200 mm diameter watermain running through the site.

Yours truly,
Tatham Engineering Limited





Randy Simpson, B.A.Sc., P.Eng. Director, Manager - Land Development JS/RS:rlh

Encl. - Site Servicing Plan, Architectural drawings, Fire Flow Calculations

copy: Travis Sandberg Dunn Capital Corporation tsandberg@dunncap.ca

I:\2023 Projects\123019 - 498 Hume Street, Collingwood\01 - FSR Update\Documents\Reports\L - 498 Hume Street Servicing Report Addendum.docx








WEST ELEVATION (DIMENSIONS)

1/8"=1'-0"



NORTH ELEVATION (DIMENSIONS)

1/8"=1'-0"









Project:	498 Hume Street, Collingwood	Date:	February 6, 2023
File No.:	123019	Designed:	EP
Subject:	Fire Flow Calculations	Checked	JRC
Revisions:			

Fire Underwriters Survey Fire Flow Calculations

Calculation Based on 2020 Publication "Water Supply for Public Fire Protection" by Fire Underwriters Survey (FUS).

	Description	Term	Options	Multiplier Associated with Option	Choose	Value used	Unit	Total Fi (L/r		
				Framing Material	•	•				
			Type V - Wood Frame Construction	1.5						
			Type IVA - Mass Timber Construction	0.8						
		Coefficient	Type IVB - Mass Timber Construction	0.9	Ordinary Construction		%			
1	Frame Use for Construction of Unit	related to type	Type IVC - Mass Timber Construction	1.0		1.0		N/A		
	Construction of onit		Type IVD - Mass Timber Construction	1.5		1.0	/0	IN/	Α	
		(C)	Ordinary Construction	1.0						
			Non-combustible Construction	0.8						
			Fire Resistive Construction	0.6						
		Largest Floor Ar	ea		•	475				
		Percentage of th	e Total Area of the Other Floors for Coeffici	ent 1.0 to 1.5	100%	475				
		Percentage of th	e Total Area of the Other Floors for Coeffici	ent below 1.0:	'					
2	Total Effective Area		opening in the building are unprotected, co reas plus 50% of all floors immediately above		50%		m²	N/.	/A	
		protected in acc	penings and exterior vertical communicatio ordance with the National Building Code, co a plus 25% of each of the two immediately a	onsider only the single	25%					
				Tota	al Effective Area	950				
3	Required Fire Flow without Reductions or Increases		Required Fire Flows	without Reductions or In	creases per FUS): (RFF= 220 x	C x A ^{0.5})		7,00	
	Factors Affecting	Reductions / Increases Due to Factors Affecting Burning								
4	Burning			ncreases Due to Factors /	Affecting Burnin	g				
4			Non-combustible	-0.25	Affecting Burning	g				
4	Burning	Occupancy			Affecting Burnin	g				
4.1	Burning Combustibility of	Occupancy content hazard reduction or	Non-combustible	-0.25	Affecting Burning Combustible	g 0	%	-	7,00	
	Burning	content hazard	Non-combustible Limited combustible	-0.25 -0.15 0.00 0.15			%	-	7,00	
	Burning Combustibility of	content hazard reduction or	Non-combustible Limited combustible Combustible	-0.25 -0.15 0.00			%	-	7,00	
	Burning Combustibility of	content hazard reduction or	Non-combustible Limited combustible Combustible Free burning	-0.25 -0.15 0.00 0.15 0.25	Combustible		%	-	7,00	
4.1	Burning Combustibility of Building Contents	content hazard reduction or surcharge	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition and automatic sprinkier protection designed and installed in accordance with	-0.25 -0.15 0.00 0.15 0.25	Combustible	0		-		
	Burning Combustibility of	content hazard reduction or	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic Sprinkler protection designed and installed in accordance with NEPA 1X b) Water supply is standard for both the system and the Fire Department hose	-0.25 -0.15 0.00 0.15 0.25 is a), b) and c) below mu	Combustible sist be met.		%	-	7,000	
4.1	Burning Combustibility of Building Contents	content hazard reduction or surcharge	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkier protection designed and installed in accordance with NEPA 13 b) Water supply is standard for both the	-0.25 -0.15 0.00 0.15 0.25 as a), b) and c) below mu	Combustible ist be met.	0		-		
4.1	Burning Combustibility of Building Contents	content hazard reduction or surcharge	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkler protection designed and installed in accordance with NEDA 1.7 b) Water supply is standard for both the system and the Fire Department hose lines	-0.25 -0.15 0.00 0.15 0.25 is a), b) and c) below mu -0.3	Combustible ust be met. No	0				
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers	content hazard reduction or surcharge	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkler protection designed and installed in accordance with hEPA 17 D) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None	-0.25 -0.15 0.00 0.15 0.25 as a), b) and c) below mu -0.3 -0.1	Combustible ust be met. No No	0				
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10%	content hazard reduction or surcharge Sprinkler reduction Exposure	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition (a) Automatic sprinkler protection designed and installed in accordance with MEDA 17 (b) Water supply is standard for both the system and the Fire Department hose lines (c) Fully supervised system	-0.25 -0.15 0.00 0.15 0.25 us a), b) and c) below mu -0.3 -0.1 -0.1 0.0	Combustible Ist be met. No No No No	0	%	1400	7,000	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between	content hazard reduction or surcharge Sprinkler reduction	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition any Automatic sprinkier protection designed and installed in accordance with NEPA 13 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development)	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 0.0 3.1 to 10.0 m	Combustible ust be met. No No No No No O.20	0		- 1,400	7,00	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire	content hazard reduction or surcharge Sprinkler reduction Exposure distance	Non-combustible Limited combustible Free burning Rapid burning For a fully supervised system the condition J Automatic sprinkler protection designed and installed in accordance with NEPA 13 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn)	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m	Combustible ust be met. No No No No 0.20 0.00	0	%	- 1,400	7,00	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between	content hazard reduction or surcharge Sprinkler reduction Exposure distance	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkler protection designed and installed in accordance with NEPA 1.3 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units)	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m	Combustible	0	%	- 1,400	7,00	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition ay automatic sprinkier protection designed and installed in accordance with NEPA 13 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units) Non-combustible roofing material	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m	Combustible Ist be met. No No No O.20 O.00 O.00 Non-	0 0.2	%		7,00	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood Shingle or Shake Roof	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for potential to	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkler protection designed and installed in accordance with NEPA 1.3 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units)	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m 0	Combustible Ist be met. No No No No O.20 O.00 O.00 O.00 Non- combustible roofing	0	%	1,400	7,00 8,40	
4.2	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprinkler protection designed and installed in accordance with NEPA 17 b) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units) Non-combustible roofing material Low risk of fire spread Moderate risk of fire spread	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m Greater than 30.0 m	Combustible Ist be met. No No No No 0.20 0.00 0.00 Non- combustible	0 0.2	%		7,00 8,40	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood Shingle or Shake Roof	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for potential to	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprimate protection designed and installed in accordance with NEDA 12 D) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units) Non-combustible roofing material Low risk of fire spread Moderate risk of fire spread High risk of fire spread	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m Greater than 30.0 m 0 2000 3000	Combustible Ist be met. No No No No 0.20 0.00 0.00 0.00 Non- combustible roofing material	0 0.2	% % L/min		7,00 8,40 8,40	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood Shingle or Shake Roof	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for potential to	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprimate protection designed and installed in accordance with NEDA 12 D) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units) Non-combustible roofing material Low risk of fire spread Moderate risk of fire spread High risk of fire spread	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m Greater than 30.0 m 0 2000 3000 4000 ow, rounded to nearest 1	Combustible Ist be met. No No No No 0.20 0.00 0.00 0.00 Non- combustible roofing material	0 0 0.2 0 max/min limit	% L/min s applied:		7,00 8,40 8,40	
4.1	Burning Combustibility of Building Contents Reduction Due to Presence of Sprinklers Separation Distance Between Units (Use 10% for 2 hour Fire Separation between adjacent units) Combustibility of Wood Shingle or Shake Roof	content hazard reduction or surcharge Sprinkler reduction Exposure distance between units Surcharge for potential to	Non-combustible Limited combustible Combustible Free burning Rapid burning For a fully supervised system the condition a) Automatic sprimate protection designed and installed in accordance with NEDA 12 D) Water supply is standard for both the system and the Fire Department hose lines c) Fully supervised system None North Side (Future Development) East Side (Building Pad 2) South Side (Holiday Inn) West Side (Storage Units) Non-combustible roofing material Low risk of fire spread Moderate risk of fire spread High risk of fire spread	-0.25 -0.15 0.00 0.15 0.25 s a), b) and c) below mu -0.3 -0.1 -0.1 -0.1 0.0 3.1 to 10.0 m Greater than 30.0 m Greater than 30.0 m Greater than 30.0 m 0 2000 3000 4000 ow, rounded to nearest 1	Combustible Ist be met. No No No No O.20 O.00 O.00 O.00 Non- combustible roofing material O00 L/min, with Total Required F	0 0 0.2 0 max/min limit	% L/min s applied: re) in L/s:	0	7,000 8,400 8,400 8,000	

123019 - FUS CalcsFUS Template-2/8/2023 1 of 1