tathameng.com



File 119106

May 10, 2023

Nathan Wukash Community Planner Town of Collingwood P.O. Box 157, 97 Hurontario Street Collingwood, Ontario L9Y 3Z5 nwukash@collingwood.ca

Re: 50 Saunders Street, Town of Collingwood

Servicing Update (Town file number: D1201120)

Dear Nathan:

The following is provided to address the sanitary and water servicing for the proposed 62-unit residential development at 50 Saunders Street in the Town of Collingwood.

PROPOSED DEVELOPMENT

The proposed development will consist of 62 single family detached lots fronting either the proposed crescent road (Street A) or Saunders Street. A 200 mm diameter sanitary sewer and 150 mm diameter watermain will be constructed along Street A to service the site from the existing 200 mm diameter sanitary sewer and 150 mm diameter watermain on Saunders Street.

WATER SUPPLY & DISTRIBUTION

The Collingwood Water Treatment Plant has a rated capacity of 31,140 m³/day during the summer and 24,019 m³/day during the winter per the Town of Collingwood Semi-Annual Water and Wastewater Uncommitted Hydraulic Reserve Capacity Update (September 2022). The 2022 Capacity Update showed an average maximum day demand of 15,279 m³/day during the summer and 9,707 m³/day during the winter, along with 10,750 m³/day of municipally committed flow during the summer and winter. This results in a hydraulic reserve capacity of 5,111 m³/day during the summer and 3,562 m³/day during the winter. When factoring in Planning Applications, Committed Servicing Capacity Allocation and a Factor of Safety, the remaining uncommitted hydraulic reserve capacity was determined to be 1,830 m³/day during the summer and 1,263 m³/day during the winter.

Water Demands Assessment

The Town of Collingwood Development Standards (2007) and Town of Collingwood Semi-Annual Water and Wastewater Uncommitted Hydraulic Reserve Capacity Update (September 2022) were used to





determine the water consumption demand for the site. The average water demand is assumed at 260 L/cap/day and the persons per unit (PPU) has been assumed at 2.90 PPU. Peak usage factors for maximum day demand and peak hour demand were determined to be 1.77 and 4.5, respectively. The maximum daily demand was calculated to be 0.96 L/s and the peak hour demand is 2.43 L/s. The maximum daily demand equates to 62 SDU using the Town's single detached unit equivalent calculation. The supporting calculations are attached.

SANITARY SEWAGE

The sewage treatment plant has an average day flow rated capacity of 24,548 m³/day and a maximum day flow rate capacity of 17,706 m³/day based on a review of the Town of Collingwood Semi-Annual Water and Wastewater Uncommitted Hydraulic Reserve Capacity Update (September 2022). The Capacity Update notes the Hydraulic Reserve Capacity of 6,842 m³/day. When factoring in Planning Applications, Committed Servicing Capacity Allocation and a Factor of Safety, the remaining uncommitted hydraulic reserve capacity was determined to be 4,427 m³/day.

Sanitary Demands Assessment

The expected sewage to be generated by the proposed site and surrounding area was calculated using the attached sanitary design sheet. It was confirmed that the existing 200 mm diameter sanitary sewer on Saunders Street has sufficient capacity to service the proposed 62 single detached units. Supporting calculations are attached for reference.

SUMMARY

Based on the preceding analysis, the development has adequate water and sanitary servicing available to support the proposed site. The site will be serviced by the existing 200 mm diameter sanitary sewer and the existing 150 mm diameter watermain on Saunders Street.

Yours truly,

Tatham Engineering Limited

Andrew Schoof, B.A.Sc., M.A.Sc.

Engineering Intern

AS:rlh

Encl.



Doris Casullo, B.A.Sc., P.Eng. Senior Engineer, Project Manager

O:\Collingwood\2019 Projects\119106 - 50 Saunders Road - Due Diligence\Documents\Correspondence\L - Wukash - Servicing Update - May 2023.docx





Project: 50 Saunders Date: May 2023

File No.: 119106 Designed: AS

Subject: Water Supply Calculations - ICBL Checked: DC

Town and MECP Standards Water Supply Calculation

Sewage Generation for Domestic Water Demand:

260 L/cap/day As per Town of Collingwood Semi-Annual Water and Wastewater

Single Detached Home

290 PPU Uncommitted Hydraulic Reserve Capacity Update (September 2022)

Total Units = 62 Number of Persons = 180 Average Daily Flow = 46748 L/day Average Daily Flow = 46.7 m 3 /day

Maximum Day Factor = 1.77 As per Town of Collingwood Semi-Annual Water and Wastewater

Uncommitted Hydraulic Reserve Capacity Update

Peak Hour Factor = 4.50 As per MOE Design Guidelines for Drinking Water Systems (2008)

Maximum Day Demand: $0.96 \text{ L/s} = 83 \text{ m}^3/\text{day} / 1.33 = 62 \text{ SDU}$

Peak Hour Demand: 2.43 L/s

Town of Collingwood Semi-Annual Water and Wastewater Uncommitted Hydraulic Reserve Capacity Update (Septmber 2022) - Appendix A

Assumptions:

 ADD/ Capita Consumption (L/day):
 260

 Residential Peaking Factor (ADD:MDD Ratio):
 1.77

 ICI Peaking Factor (ADD:MDD Ratio):
 2.5

 Commercial Area ADD (m3/ha/day)
 28

 Industrial Area ADD (m3/ha/day)
 35

 Institutional Area ADD (m3/ha/day)
 28

Residential Types Legend
Residential - Single Detached Home (2.9 ppl/unit)
Residential - Semi Detached (2.7 ppl/unit)
Residential - Townhouse/ Row-House (2.4 ppl/unit)
Residential - Condo/ Apartment (1.9 ppl/unit)

MDD (m3/d) 1.33 1.24 1.10 0.87
 Residential Types Legend
 SDU-E

 Residential - Single Detached Home (2.9 ppl/un 1.00
 1.00

 Residential - Semi Detached (2.7 ppl/unit)
 0.93

 Residential - Townhouse/ Row-House (2.4 ppl/u 1.00
 0.83


 Residential - Condol Apartment (1.9 ppl/unit)
 0.66



Jeremy Acres

Project Information 50 Saunders Street 119106 Drawing Reference SAN01 Prepared By Andrew Schoof May 2023 Reviewed By

May 2023



Municipality Town of Collingwood Flow Rates Average (L/cap/day) Infiltration (L/s/Ha)

Population Density Cap/ Unit Low Med High 2.90 - -

260

0.23


Manning's Coefficient

Pipe	Value
Conc.	0.013
PVC	0.013
Assumed	0.013

									AVERAGE FLOW (L/s)			PEA	K FLOW (L/s)	PROPOSED SANITARY SEWER							
STREET NAME	AREA LABEL / ID	UPSTREAM MANHOLE	DOWNSTREAM MANHOLE	NUMBER OF UNITS	POPULATION (cap)	ACCUMULATED POPULATION (cap)	PEAKING FACTOR (HARMON)	AREA (Ha)	ACCUMULATED AREA (Ha)	RESIDENTIAL	INFILTRATION	TOTAL	RESIDENTIAL	INFILTRATION	TOTAL	LENGTH OF PIPE (m)	PIPE DIAMETER (mm)	GRADE (%)	FULL FLOW CAPACITY (L/s)	PERCENT OF FULL FLOW (%)	FULL FLOW VELOCITY (m/s)	ACTUAL VELOCITY (m/s)
Street A	2	MH2	МН3	9	26.1	26.1	4.36	0.55	0.55	0.08	0.13	0.21	0.34	0.13	0.47	65.6	200	1.0%	32.80	1.4%	1.04	0.38
Street A	3	МН3	MH4	2	5.8	31.9	4.35	0.19	0.74	0.10	0.17	0.27	0.42	0.17	0.59	10.2	200	0.6%	25.40	2.3%	0.81	0.34
Street A	4	MH4	MH5	12	34.8	66.7	4.29	0.74	1.48	0.20	0.34	0.54	0.86	0.34	1.20	82.4	200	0.6%	25.40	4.7%	0.81	0.41
Street A	5	MH5	МН6	12	34.8	101.5	4.24	0.72	2.20	0.31	0.51	0.81	1.30	0.51	1.80	80.2	200	0.6%	25.40	7.1%	0.81	0.46
Street A	6	МН6	MH7	3	8.7	110.2	4.23	0.22	2.42	0.33	0.56	0.89	1.40	0.56	1.96	12.5	200	0.6%	25.40	7.7%	0.81	0.47
Street A	7	MH7	МН8	5	14.5	124.7	4.22	0.29	2.71	0.38	0.62	1.00	1.58	0.62	2.21	46.6	200	0.6%	25.40	8.7%	0.81	0.48
Street A	8	МН8	МН9	3	8.7	133.4	4.21	0.22	2.93	0.40	0.67	1.08	1.69	0.67	2.36	27.0	200	0.6%	25.40	9.3%	0.81	0.49
Street A & Saunders St	9	МН9	MH28A	2	5.8	139.2	4.20	0.13	3.06	0.42	0.70	1.12	1.76	0.70	2.46	26.3	200	0.6%	25.40	9.7%	0.81	0.50
Poplar Sideroad	A12	MH51A	MH50A	5	14.5	14.5	4.40	0.85	0.85	0.04	0.20	0.24	0.19	0.20	0.39	86.7	200	1.0%	32.80	1.2%	1.04	0.36
Poplar Sideroad	A13	MH50A	МН30А	5	14.5	29.0	4.36	0.75	1.60	0.09	0.37	0.46	0.38	0.37	0.75	120.0	200	0.4%	20.74	3.6%	0.66	0.31
Saunders Street	0	МН30А	MH1A	0	0.0	29.0	4.36	0.11	1.71	0.09	0.39	0.48	0.38	0.39	0.77	62.0	200	0.45%	22.00	3.5%	0.70	0.33
Street A	1	MH2	MH1	7	20.3	20.3	4.38	0.42	0.42	0.06	0.10	0.16	0.27	0.10	0.36	50.3	200	5.0%	73.33	0.5%	2.33	0.64
Street A	-	MH1	MH1A	0	0.0	20.3	4.38	0.00	0.42	0.06	0.10	0.16	0.27	0.10	0.36	11.8	200	5.0%	73.33	0.5%	2.33	0.64



Project Information 50 Saunders Street 119106 Drawing Reference SAN01 Prepared By Andrew Schoof May 2023 Reviewed By Jeremy Acres May 2023



Municipality

Town of Collingwood

Flow Rates

Average (L/cap/day)	260
Infiltration (L/s/Ha)	0.23

Population Density

Cap/	Low	Med	High
Unit	2.90	-	-

Pipe	Value
Conc.	0.013
PVC	0.013
Assumed	0.013

								AVERAGE FLOW (L/s)			PEA	K FLOW (L/s)	PROPOSED SANITARY SEWER								
STREET NAME	AREA LABEL / ID	UPSTREAM MANHOLE	DOWNSTREAM MANHOLE	NUMBER OF UNITS	POPULATION (cap)	ACCUMULATED POPULATION (cap)	PEAKING FACTOR (HARMON)	АREA (На)	ACCUMULATED AREA (Ha)	RESIDENTIAL	INFILTRATION	TOTAL	RESIDENTIAL	INFILTRATION	TOTAL	LENGTH OF PIPE (m)	PIPE DIAMETER (mm)	GRADE (%)	FULL FLOW CAPACITY (L/s)	PERCENT OF FULL FLOW (%)	FULL FLOW VELOCITY (m/s)	ACTUAL VELOCITY (m/s)
Saunders Street	10	MH1A	МН29А	3	8.7	58.0	4.30	0.47	2.60	0.17	0.60	0.77	0.75	0.60	1.35	58.0	200	0.45%	22.00	6.1%	0.70	0.38
Stephens St	A25	МН38А	МН37А	10	29.0	29.0	4.36	1.09	1.09	0.09	0.25	0.34	0.38	0.25	0.63	101.1	200	0.5%	23.19	2.7%	0.74	0.32
Stephens St	A26	MH37A	МН29А	4	11.6	40.6	4.33	0.62	1.71	0.12	0.39	0.52	0.53	0.39	0.92	110.0	200	0.5%	23.19	4.0%	0.74	0.36
Saunders St	11	MH29A	MH28A	10	29.0	127.6	4.21	1.14	5.45	0.38	1.25	1.64	1.62	1.25	2.87	122.4	200	0.4%	20.74	13.8%	0.66	0.45
Mary Street	A28	МН36А	MH28A	7	20.3	20.3	4.38	0.94	0.94	0.06	0.22	0.28	0.27	0.22	0.48	120.0	200	1.0%	32.80	1.5%	1.04	0.38
Saunders St	A17	MH28A	MH27A	2	5.8	292.9	4.08	0.54	9.99	0.88	2.30	3.18	3.60	2.30	5.90	122.4	200	0.37%	19.95	29.6%	0.63	0.53

Note

^{1.} Population Density of 2.90 determined from Town of Collingwood Semi-Annual Water and Wastewater Uncommitted Hydraulic Reserve Capacity Update (September 2022)