







Sample Drawing <u>ROOF RAFTERS</u> (FLAT ROOF - WHERE NO CEILING IS INSTALLED)

| MAXIMUM CLEAR SPAN (M) | | | | | | | |
|------------------------|--------------------------|------|------|--------------------------|------|------|--|
| RAFTER SIZE | ROOF SNOW LOAD I.OKPa | | | ROOF SNOW LOAD 1.5kPa | | | |
| | RAFTER SPACING (mm) O.C. | | | RAFTER SPACING (mm) O.C. | | | |
| | 300 | 400 | 600 | 300 | 400 | 600 | |
| 38×89 | 3.11 | 2.83 | 2.47 | 2.72 | 2.47 | 2.16 | |
| 38×140 | 4.90 | 4.45 | 3.89 | 4.28 | 3.89 | 3.40 | |
| 38×184 | 6.44 | 5.85 | 5.11 | 5.62 | 5.11 | 4.41 | |
| 38×235 | 8.22 | 7.47 | 6.38 | 7.18 | 6.52 | 5.39 | |

ROOF JOISTS

(FLAT ROOF - WHERE CEILING IS INSTALLED)

| MAXIMUM CLEAR SPAN (M) | | | | | | | |
|------------------------|-------------------------|------|------|-------------------------|------|------|--|
| JOIST SIZE | ROOF SNOW LOAD I.OKPA | | | ROOF SNOW LOAD 1.5kPa | | | |
| | JOIST SPACING (mm) O.C. | | | JOIST SPACING (mm) O.C. | | | |
| | 300 | 400 | 600 | 300 | 400 | 600 | |
| 38×140 | 3.89 | 3.53 | 3.08 | 3.40 | 3.08 | 2.69 | |
| 38×184 | 5.11 | 4.64 | 4.05 | 4.46 | 4.05 | 3.54 | |
| 38×235 | 6.52 | 5.93 | 5.18 | 5.70 | 5.18 | 4.52 | |
| 38×286 | 7.94 | 7.21 | 6.30 | 6.94 | 6.30 | 5.50 | |

LINTELS

| DOOR WIDTH | LINTELS FOR WOOD FRAMING | | LINTELS FOR BRICK VENEE | R 90mm | LINTELS FOR SOLID MASONRY 200mm | |
|-----------------|-------------------------------|--------------------------------------|-------------------------------|------------------------------|------------------------------------|---------------------------|
| | NOT SUPPORTING THE ROOF | SUPPORTING THE ROOF | NOT SUPPORTING THE ROOF | SUPPORTING THE ROOF | NOT SUPPORTING THE ROOF | SUPPORTING THE ROOF |
| UP TO 3000mm | 2/38×184 | 2/38×286 | 2/38x184 + ANGLE 125x90x8 | 2/38x286 + ANGLE 125x90x8 | 2 ANGLES I50x100x10 | WI50x22 + PLATE 200x10 |
| UP TO 4900mm | 2/38×286 | 4/38×286 OR 2- 45×300 I.9E LVL | W200x27 + PLATE 200x10 | W200x27 + PLATE 200x10 | MUST BE DESIGNED | MUST BE DESIGNED |

GENERAL NOTES

I. ALL LUMBER TO BE NO. 1\$2 SPRUCE OR BETTER

- 2. ALL PLYWOOD SHALL BE STAMPED EXTERIOR GRADE
- 3. ROOF LOAD DESIGN I.O kPa OR I.5 kPa
- 4. ALL FOOTINGS TO BEAR ON UNDISTURBED SOIL.
- 5. IF GARAGE WALL IS LESS THAN 600mm TO THE PROPERTY LINE PROVIDE 15.9mm TYPE 'X' DRYWALL INTERIOR SHEATHING. NO WINDOWS ARE PERMITTED IN GARAGE WALLS LESS THAN 1200mm FROM PROPERTY LINE.
- 6. FOR ONE STOREY WOOD FRAME DETACHED GARAGES LESS THAN 55M2. AN ALTERNATE FOOTING MAY BE USED, SEE DETAIL SHEET GO2C
- GARAGE SLAB SHALL BE 32 Mpa CONCRETE W/ 5% 8% AIR ENTRAINMENT SLOPED TO DRAIN TO THE OUTSIDE.
- 8. ROOF SHEATHING SHALL BE MIN. 9.5mm PLYWOOD PROVIDE 'H' CLIPS IF RAFTERS OR JOISTS ARE SPACED GREATER THAN 400mm O.C.
- 9. PROVIDE A LIGHT FIXTURE IN THE GARAGE.

TITLE

- 10. STEEL BEAMS TO BE SUPPORTED BY SOLID MASONRY (190mm BEARING ON MASONRY OR 73mm DIA. STEEL COLUMN).
- II. LINTELS AND BEAMS TO BE DESIGNED BY A QUALIFIED PERSON FOR SPANS GREATER THAN 4900mm

These drawings and are provided for **information purposes only.** They do not necessarily represent every detail of building construction, or all minimum standards which apply. For more detailed information about construction regulations refer to the Ontario Building Code, or a qualified designer.



DETACHED GARAGE TABLES & NOTES DWG. NO.

2007

G02b